

DATE SUBMITTED 01/31/2024
 SUBMITTED BY Public Services
 DATE ACTION REQUIRED 02/07/2024

COUNCIL ACTION ()
 PUBLIC HEARING REQUIRED ()
 RESOLUTION ()
 ORDINANCE 1ST READING ()
 ORDINANCE 2ND READING ()
 CITY CLERK'S INITIALS ()

**IMPERIAL CITY COUNCIL
 AGENDA ITEM**

SUBJECT: Continue Emergency of VFD at WTP	DISCUSSION/ACTION: 1. DISCUSS, APPROVE/DISAPPROVE: CONTINUTATION OF EMERGENCY OF VFD AT THE WATER TREATMENT PLANT
DEPARTMENT INVOLVED: <u>Public Services – WTP</u>	
BACKGROUND/SUMMARY: On Thursday, December 21, 2023, it was determined a Variable Frequency Drive (VFD) has failed at the WTP that provide function to one of the three finished water pumps. This pump is critical to the treatment process that allows sufficient pressure to deliver water through our GAC filtration system in our treatment process. An emergency was declared by the City Manager that same day. Repairs have been completed. Pending final invoicing from Vendors.	
FISCAL IMPACT: <u>Unknown</u>	FINANCE INITIALS <u>JMS</u>
STAFF RECOMMENDATION: <u>Continue Emergency</u>	DEPT. INITIALS <u>[Signature]</u>
MANAGER'S RECOMMENDATION: <u>approve continuation</u>	CITY MANAGER'S INITIALS <u>JDM</u>
MOTION: SECONDED: AYES: NAYES: ABSENT:	
APPROVED () REJECTED () DISAPPROVED () DEFERRED () REFERRED TO:	