

CITY OF IMPERIAL
“7TH, 10TH & 14TH STREETS
REHABILITATION PROJECT”
Bid No. 2024-01

ADDENDUM No. 3
04/12/2024

TO THE CONTRACT DOCUMENTS AND SPECIFICATIONS.

Bidders are advised that the contract documents and specifications for the above referenced contract are hereby amended in the following manner and the following manner only:

This Addendum answers bidder’s questions:

1. BID documents are requesting removal and installation of several sewer manholes. Does the scope-of-work include the existing base?

YES, the targeted manholes shall be removed and replaced entirely per Items 20, 21 & 22.

2. In your items for fire hydrants remove and replace, what exactly is the scope. Are we removing the entire burry and pipe up to the gate valve as shown in City standard plan or are we simply replacing the fire hydrant and positive break-off check valve assembly. Please advise


The Scope of Work of Item 19 includes full removal and replacement of those four (4) fire hydrants as they will be relocated to a slightly different location and the actual fire hydrants shall be retrofitted.

All work per “PROPOSAL BID SHEET” included in the “CONTRACT DOCUMENTS AND SPECIFICATIONS” (Rev 1) dated April 3, 2024.

See Addendum No. 2 dated 04/05/2024.

Please acknowledge receipt of this addendum by signing and returning a copy of the Acceptance of Notice by fax to (760) 355-4718. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Sheet Proposal.

Include a copy of this addendum with your Bid Proposal Package. It is the Contractor's responsibility to notify its sub-contractors about changes based all addendums.

P.P. 

Date 04/12/2024

By: Othon Mora
Community Development Director

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 3 is hereby acknowledged by

Bidder's Company Name

Date _____

By _____
Type or Print Name & Signature

Title _____