

**CITY OF IMPERIAL**  
**IMPERIAL, CALIFORNIA**

**ADDENDUM NO. 2**

**WASTEWATER TREATMENT PLANT**

**HEADWORKS UPGRADE**

**BID NO. 2015-08**

Bidders are advised that the plans and specifications for the above referenced contract are hereby amended in the following manner and the following manner only:

**A. GENERAL**

1. All provisions of this Addendum No. 2 are hereby incorporated into the Contract Documents and bidders shall account for all provisions pursuant to this Addendum No. 1 in submitting their bid proposals. **Each Bidder shall include a dated and signed copy of this Addendum No. 2 with his sealed bid proposal.**

**B. CLARIFICATIONS**

1. Specification Section 033000, Subsection 1.3, Item A.7 Strength Requirements
  - a. Section 1.3, Subsection A, Item 7 Strength Requirements
    - i. The statement shall be revised to read; The specified compressive strength (F'c) and other characteristics of the concrete shall be as stated in Table A.

<b>Table A – Cast in Place Concrete</b>				
<b>Concrete Use</b>	<b>Compressive Strength f'c at 28 days (psi)</b>	<b>Max. New Water to Cement Ratio by Weight</b>	<b>Min Cement Per Cubic Yard of Concrete (lbs)</b>	<b>Slum Range (in)</b>
All Concrete Except Electrical Encasements	4,500	0.45	658	2 to 4
Electrical Encasements	2,500	0.71	564	3 to 6

Note: Concrete shall be made with Type V low alkali cement.



By: Brian P. Knoll 8/31/2015  
Brian P. Knoll date  
P.E. CA65690

By: \_\_\_\_\_  
(Bidder's Company Name)

Date Received by Bidder:

\_\_\_\_\_  
(Bidder's Signature)

\_\_\_\_\_

\_\_\_\_\_  
(Type or Print Name)

**Bidder shall include a signed copy of this Addendum No. 2 with the bid proposal.**