CITY OF IMPERIAL

"PUBLIC LIBRARY EXPANSION PROJECT"
Bid No. 2015-10

ADDENDUM No. 5

09/9/2015

TO THE CONTRACT DOCUMENTS AND SPECIFICATIONS

1. ***QUESTION*: WILL THE CURB AROUND THE SIDEWALK BE STANDARD 6" BY 18" CURB?** Yes.

2. **CLARIFICATION:** See revision cloud No 4 and cross section A-A for contactors reference.

3. **QUESTION: PLANS SHOW 2' GRANULAR FILL UNDER SIDEWALKS? IS THAT REQUIRED?** Yes, as per Geotechnical report.

4. **WHERE DO WE NEED TO INSTALL THE FIRE SPRINKLERS?** Throughout the entire building, new fire line to connect on G Street (plans to be provided by contractor).

5. **IS HC RAMP IN FRONT INCLUDED IN THIS BID?** HC ramp north of the project is not included.

6. **ARE STUDY CORRALS LAMINATE?** Yes, please see keynote 6 on sheet A-5.

7. **CLARIFICATION:** Wall and door relocated and added to Sheet A-5, please see attached copy revision cloud No 3.

Please acknowledge receipt of this addendum by signing and returning a copy of the Acceptance of Notice by fax to (760) 355-4718. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Sheet Proposal.

Include a copy of this addendum with your Bid Proposal Package. It is the Contractor's responsibility to notify its sub-contractors about changes based all addendums.

By: Debra Jackson, City Clerk

Date September 9, 2015

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 5 is hereby acknowledged by

_____ Date_____

Bidder's Company Name

By_____ Title_____

Type or Print Name & Signature