Agenda Item No. 2-2

DATE SUBMITTED

February 12, 2020

SUBMITTED BY

Public Services

DATE ACTION REQUIRED

February 19, 2020

COUNCIL ACTION PUBLIC HEARING REQUIRED RESOLUTION ORDINANCE 1ST READING ORDINANCE 2ND READING CITY CLERK'S INITIALS



IMPERIAL CITY COUNCIL AGENDA ITEM

SUBJECT: Professional						
Services VFD	1. Discuss, Approve/Disapprove hire of professional services for VFD installation.					
DEPARTMENT INV	OLVED: Public Services			5		
BACKGROUND/SU	MMARY:					
Requesting to hir	e Sulzer, for their professional services, to	install elect	ronic variable fr	requency drive at		
Aten Booster Sta				1 2		
1						
FISCAL IMPAC	Γ: \$8,740.00 Sulzer		FINANCE INITIALS	14		
			INITIALS	1/)		
100% Water GL: 50-510-5241				10		
STAFF RECOMMEN	NDATION: Approval			10		
			DEPT. INITIALS	d) 197		
				7		
MANAGER'S RECO	MMENDATION: Approval		CITY			
	approve.		MANAGER's INITIALS	OHM		
-	//	,				
MOTION:						
SECONDED: APPROVED AYES: DISAPPROV		() ED ()	REJECTED () DEFERRED ()			
NAYES: ABSENT:	JAYES:			50		



Phone 909-825-7971 Fax 909-825-6312 620 So. Rancho Ave, Colton, CA 92324-3243

A.LIC 822429

Refer to:

Quote No 32134

Date 2/13/2020

Imperial, City of

420 South Imperial Avenue

Imperial

CA

92251

Ph. No.

Freight

Υ	our	contact	at	Sulzer	EMS:
---	-----	---------	----	--------	------

Eleanor Corgan for Jesse

Terr.

Н

Description	Unit Price	Delivery	FOB
Project Aten Booster #1 Replacement			
-			
Scope: Replace 150Hp Toshiba W7 VFD Power Unit with Toshiba AS3.			
Reconnect Power and Control Wiring			
Labor to install	\$8,740.00		
* Price reflects prevailing wage rate required in California.			

Sales Tax is additional if applicable. Prices good for 30 days, subject to change without notice.
Please Note: that this is not an offer to contract, but merely a quotation of current prices for your convenience and
information. Orders based on this quotation are subject to our acceptance on the terms and conditions stated in our
written Acknowledgment of order. We make no representations with respect to compliance with job specifications.

Comments			
1			
1			
1			