		Agenda Item No. 7-2	
DATE SUBMITTED	04/13/22	COUNCIL ACTION	(x)
SUBMITTED BY	Public Services	PUBLIC HEARING REQUIRED RESOLUTION	()
DATE ACTION REQUIRED	04/20/22	ORDINANCE 1 ST READING ORDINANCE 2 ND READING CITY CLERK'S INITIALS	az

IMPERIAL CITY COUNCIL AGENDA ITEM

SUBJECT: Purchase Flowmeter System 1. Approve purchase of Electromagnetic	Flowmeter System	for WWTP.		
DEPARTMENT INVOLVED: Public Services - WWTP				
BACKGROUND/SUMMARY:				
Requesting to purchase an Electromagnetic Flow Meter Sy Wastewater Plant for required State flow reporting.	stem for the com	nbined effluent	at the	
FISCAL IMPACT: \$9,997.00 (plus start up fees, taxes & freight) - MCR Tech 35.520.5442	INI	NANCE ITIALS	18	
STAFF RECOMMENDATION: Approve	DE	EPT. INITIALS	ple	
MANAGER'S RECOMMENDATION:	MA	TY ANAGER's IITIALS	DAM	-
MOTION:				
SECONDED: AYES: NAYES: ABSENT:	APPROVED DISAPPROVED REFERRED TO:	() I)

QUOTATION# 18982

Certified Small Business ID# 1368500

Date: April 7, 2022, 2:25:10 PM

Company:

City of Imperial

Attention:

Christopher Kemp

Phone Number: E-mail:

(760) 457-5772 ckemp@cityofimperial.org

Quotation Valid: F.O.B. Point:

June 30, 2022

Payment Terms:

Factory Net 30

Reference:

18" WaterMaster ABB

Manufacturer: Lead Time:

TBD

Freight Terms:

Prepaid & Add

Prepared By: Kyle Finney

(949) 783-3100

sales@mcrt.com

Thank you for the opportunity to provide you with the following quotation.

Part Number	Quantity	Unit Price	Price
FEW325.450.H.1.S.4.A1.B.1.A.1.A.3.P.2.B.3.A.1JBM5V3T3	1.00	\$9,997.00	\$9,997.00

ABB WaterMaster FEW325 Electromagnetic Flowmeter system, full bore, remote mount

- Bore Diameter 450 DN 450 (18 in.)
- Liner Material H Hard rubber
- Electrode Design 1 Standard
- Measuring Electrodes Material S Stainless steel 316
- Grounding Accessories 4 2x Potential Equalizing Rings (Stainless Steel
- Process Connection Type A1 Flanges ANSI / ASME B16.5 / 16.47 series B Class 150
- Process Connection Material B Carbon steel
- Usage Certifications 1 Standard (without PED)
- Calibration Type A Standard factory calibration
- Temperature Range of Installation / Ambient 1 Standard design / -20 ... 60 ° (-4 ... 140 °)

Temperature Range

- Name Plate A Adhesive label
- Signal Cable Length and Type 3 20 m (approx. 60 ft) cable
- Explosion Protection Certification P usFMc Div. 2
- Protection Class Transmitter / Protection Class Sensor 2 IP 67 (NEMA 4X) / IP 68 (NEMA 6P), cable not fitted and not potted, sensor is IP67 with PTFE liner
- Cable Conduits B NPT 1/2 in.
- Power Supply 3 100 ... 230 V AC, 60 Hz
- Input and Output Signal Type A HART + 20 mA + Pulse + Contact output
- Configuration Type / Diagnostics Type 1 Parameters set to factory defaults / Standard diagnostic functions activated
- Lav Length JB ISO Lav Length
- Documentation Language M5 English (standard)
- Verification Type V3 VeriMaster
- Number of Testpoints T3 3 Points

Note	1.00	\$0.00	\$0.00
-Freight, sales tax, and start up are not included.	•		
		Total	\$9,997.00

Please issue your purchase order to: MCR Technologies, Inc. P.O. Box 80640 RSM, CA 92688-0640

E-mail your purchase order to: orders@mcrt.com or Fax to (949) 783-3101

This quotation is for the products and services listed above only. Any additional products required will be provided at additional cost. Freight charges are an estimate only. Actual freight cost may vary.

This quotation is for the products and services listed above only. Any additional products required will be provided at additional cost. Freigi Tarms Included by reference This quotation is offered subject to ours and the manufacturers terms and conditions. A copy of these conditions is available upon request. MCR Technologies, Inc. is an independent manufacturers representative and distributor.

Delivery is based on current lead times and on the longest lead time of all equipment quoted. Actual delivery may vary based on the lead times in effect when the equipment is released for production Materials of Construction

Me offer a variety of material selections and configurations to suite process conditions. Although we have quoted the materials which were specified, or if not specified, which we believe to be satisfactory, we do not warrant that they are compatible with the chemicals, concentrations and operating conditions which will be encountered in the application. The final selection of the appropriate material is the responsibility of the customer.