

DATE SUBMITTED 08/26/2020  
 SUBMITTED BY Public Services  
 DATE ACTION REQUIRED 09/02/2020

COUNCIL ACTION  
 PUBLIC HEARING REQUIRED   
 RESOLUTION   
 ORDINANCE 1<sup>ST</sup> READING   
 ORDINANCE 2<sup>ND</sup> READING   
 CITY CLERK'S INITIALS JS

**IMPERIAL CITY COUNCIL  
 AGENDA ITEM**

SUBJECT: <b>DISCUSSION/ACTION: Declare Emergency at Hwy 86 &amp; Aten Rd.</b> Manhole Hwy 86 & Aten Rd.                      1. Continue Emergency Action of Resolution NO. 2020-53.	
DEPARTMENT INVOLVED:    Public Services – Waste Water	
BACKGROUND/SUMMARY:  On the afternoon of August 12 <sup>th</sup> staff reviewed and discovered a force main that feeds into Clark Pump Lift Station had broken inside a man hole located at Hwy 86 & Aten Rd. on south eastern corner.  After further review with City Manager and Assistant Manager, emergency action was declared.  Public Services is continuing to work with A&R to begin repairs and locate parts.  At this time cost and time frame to complete are still unknown.	
FISCAL IMPACT: Unknown	FINANCE INITIALS <u>JS</u>
STAFF RECOMMENDATION: Council continues approval of emergency action	DEPT. INITIALS <u>JS</u>
MANAGER'S RECOMMENDATION: <u>approve</u>	CITY MANAGER'S INITIALS <u>JS</u>
MOTION:	
SECONDED: AYES: NAYES: ABSENT:	APPROVED    ( <input type="checkbox"/> )                      REJECTED    ( <input type="checkbox"/> ) DISAPPROVED ( <input type="checkbox"/> )                      DEFERRED    ( <input type="checkbox"/> )  REFERRED TO: