

DATE SUBMITTED

08-09-2020

SUBMITTED BY

Public Services Dir.

DATE ACTION REQUIRED

08-16-2020

Agenda Item No

E-2

CITY COUNCIL ACTION (X)

PUBLIC HEARING REQUIRED ()

RESOLUTION ()

ORDINANCE 1ST READING ()

ORDINANCE 2ND READING ()

CITY CLERK'S INITIALS

[Handwritten initials]

**IMPERIAL CITY COUNCIL
AGENDA ITEM**

SUBJECT: DISCUSSION/ACTION: EMERGENCY AT HWY 86 & ATEN RD. - SEWER MANHOLE.

1. APPROVAL TO CONTINUE THE EMERGENCY ACTION TAKEN ON AUGUST 19, 2020.

DEPARTMENT INVOLVED: Public Services - Wastewater

BACKGROUND/SUMMARY:

On the afternoon of August 12, 2020 staff discovered a force main that feeds into the Clark Pump Lift Station had broken inside a manhole located at Hwy 86 & Aten on the south east corner.

An emergency was declared and public services department is working with A & R Construction to make repairs.

At the time of agenda preparation, some parts have been received and we are waiting on trenching box availability.

FISCAL IMPACT: Unknown

[Handwritten initials]

STAFF RECOMMENDATION: City Council continues emergency action.

MANAGER'S RECOMMENDATION: *approve*

MANAGER'S INITIAL *atm*

MOTION:

SECONDED:	APPROVED ()	REJECTED ()
AYES:	DISAPPROVED ()	DEFERRED ()
NAYES:		
ABSENT:	REFERRED TO:	