

CITY OF IMPERIAL

“PLAYGROUND SURFACING IMPROVEMENT PROJECT”

Bid No. 2020-06

ADDENDUM No. 1

06/30/2020

1. What is a TPV granule size?

The TPV granule size that will be required for new surfacing installations at Sky Ranch Park, Victoria Park and Savanna Ranch Park will be 0.5mm – 1.5mm.

2. What is the color mixture required at Victoria Park?

The color mixture that will be required for surfacing installation is Beige (50%) and Brown (50%).


3. What is the color mixture required at Savanna Ranch Park?

The color mixture that will be required for surfacing installation is Standard Green (50%) and Dark Grey (50%).

4. What is the color mixture required at Sky Ranch Park?

The color mixture that will be required for surfacing installation is Standard Blue (50%) and Dark Grey (50%).

Include a copy of this addendum with your Bid Proposal Package. It is the Contractor's responsibility to notify its sub-contractors about changes based all addendums.


By: Debra Jackson, City Clerk

Date: June 30, 2020

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 1 is hereby acknowledged by

Bidder's Company Name

Date _____

By _____ Title _____
Type or Print Name & Signature