

CITY OF IMPERIAL

“Aten Boulevard & Cross Road Improvements”

Bid No. 2019-03

ADDENDUM No. 2

05/22/2019

1. What conventional mix for asphalt, 1/2” or 3/4”?

The conventional mix for asphalt is 1/2”

Please acknowledge receipt of this addendum by signing and returning a copy of the Acceptance of Notice by fax to (760) 355-2548. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Sheet Proposal.

Include a copy of this addendum with your Bid Proposal Package. It is the Contractor’s responsibility to notify its sub-contractors about changes based all addendums.


By: Debra Jackson, City Clerk

Date **May 22, 2019**

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 2 is hereby acknowledged by

Bidder’s Company Name

Date

By _____ Title _____
Type or Print Name & Signature