

**CITY OF IMPERIAL**

**“Aten Boulevard & Cross Road Improvements”**

**Bid No. 2019-03**

**ADDENDUM No. 3**

05/30/2019

This Addendum answers bidder’s questions.

**1. During the pre-construction meeting a question was brought up regarding the DBE goal.**

DBE goal has been removed from this bidding process due to this project will be constructed entirely with local and LTA Measure D funding. No federal money will participate in this construction.


**2. What conventional mix for asphalt, ½” or ¾”?**

This addendum is a correction to addendum #2.

The nominal maximum aggregate size for the mix is ¾”. The contractor shall install Type A Hot Mix Asphalt (HMA) conforming to Section 39-2.02 of Caltrans Standard Specifications 2018 Edition. Contractor to submit for review/approval a Caltrans approved Hot Mix Asphalt verification form CEM-3513, a minimum of 15 days prior to the beginning of the work. No recycled asphalt concrete is allowed for this project.

Please acknowledge receipt of this addendum by signing and returning a copy of the Acceptance of Notice by fax to (760) 355-2548. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Sheet Proposal.

**Include a copy of this addendum with your Bid Proposal Package. It is the Contractor’s responsibility to notify its sub-contractors about changes based all addendums.**

  
By: Debra Jackson, City Clerk

Date **May 30, 2019**

**ACCEPTANCE OF NOTICE**

Receipt of the ADDENDUM No. 3 is hereby acknowledged by

\_\_\_\_\_  
Bidder’s Company Name Date \_\_\_\_\_

By \_\_\_\_\_ Title \_\_\_\_\_  
Type or Print Name & Signature