

CITY OF IMPERIAL

**“SIDEWALK & ADA RAMPS AT 7TH AND K STREET
INTERSECTION”**

Bid No. 2019-01

ADDENDUM No. 4

03/08/2019

This Addendum answers Granite Quality Builders questions as per Pre-Bid meeting celebrated on March 07, 2019 at 10:00am.

1. A sawcut strip at asphalt would be necessary to ensure the right position of forms and elevation for PCC Aprons and Curb & Gutters?

*As indicated on approved set of plans Demolition Keynote No. 2, sawcut, remove and replace adjacent existing ac pavement as necessary (1.00' minimum). Coordinate with city engineering division staff. Receipts from approved disposal center will be required. Please refer to Construction Keynote No. 1 as per approved set of plans. **1.00' Min. Sawcut, Removal and Replacement of existing asphalt shall be provided in regards to ensure the right elevation for all Off-Site improvements to be constructed.***


2. We have been looking for City Standard Details on the City's website but we haven't found them, are they available?

Yes, as explained on Pre-Bid Meeting, our Standard Drawing Details are in an updating process and are not available thru the website but, the updated version of these standards will be provided attached to this document.

3. Our quantities don't match with those provided by Proposal Bid Sheet.

Please see attached revised Proposal Bid Sheet.

Include a copy of this addendum with your Bid Proposal Package. It is the Contractor's responsibility to notify its sub-contractors about changes based all addendums.


By: Debra Jackson, City Clerk

Date Mach 08, 2019.

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 4 is hereby acknowledged by

Bidder's Company Name

Date

By _____ Title _____
Type or Print Name & Signature